

**ADDENDUM NO. 2
FOR
LOCSD PROGRAM C WELL EQUIPPING PROJECT**

DATE: September 12, 2023

FROM: Wallace Group
612 Clarion Court
San Luis Obispo, CA 93401
Tel: (805) 544-4011

TO: Prospective Bidders

This addendum forms a part of the Contract Documents and modifies the original Procurement Documents dated July 2023 as noted herein. Each bidder shall acknowledge receipt of this Addendum by completing the acknowledgment at the end of this Addendum, and by confirming receipt of this addendum on the contract Bid Form. Failure to do so may subject Bidder to disqualification.

The following changes or clarifications have been made to the Bid Documents:

CHANGES TO PRIOR ADDENDA:

1. None.

CHANGES TO PROCUREMENT REQUIREMENTS:

2. Notice Inviting Bids, Page 1, Bid Opening. Bid opening date is changed from September 14, 2023, to September 19, 2023. Time and location of bid opening remains unchanged.

CHANGES TO CONTRACTING REQUIREMENTS:

3. None.

CHANGES TO SPECIFICATIONS:

4. Section 43 21 54, Submersible Vertical Turbine Well Pumps, Paragraph 2.01.B, Pump Data Table, change Minimum Column Size from 3 inches to 4 inches, to match that indicated on the drawings.
5. Section 32 31 13, Aluminum Chain Link Fences and Gates, Para. 2.06 Filler Strips, replace paragraph with the following: "HDPE filler strips for vertical installation into chain link fence and gate shall be fabricated from High Density Polyethylene (HDPE), color pigments and ultraviolet (UV) inhibitors. Provide bottom locking channel. Strips shall be at least 1 3/32 inches by 6 feet long and dark green in color. Slats shall be Pexco Bottom Lock 2", Blade Slat Bottom Locking 4000 Series, or approved equal."

CHANGES TO DRAWINGS:

6. Drawing C-02, Wellhead Piping Section A-A. Modify callout to existing well casing diameter, changing dimension from 10.75" to 12" diameter.
7. Drawing S-05, North, South, East and West Elevations. Regarding the note pertaining to split face block wall, delete "COLOR MATCH AND CONFORM TO COUNTY STANDARD", and replace with "SUBMIT COLOR SAMPLE FOR REVIEW AND APPROVAL BY OWNER PRIOR TO ORDERING MATERIALS. COLOR TO MATCH

CLOSELY TO EXISTING COUNTY BLOCK WALL BUILDING LOCATED AT THE 8TH AND EL MORO WATER YARD.”

OTHER CLARIFICATIONS:

8. Section 088000, Glazing. Section applies to the windows in the building doors.
9. Section 09 90 00, Painting and Coating. Regarding System 71 (flat finish on exterior concrete and cement), no exterior concrete coatings are required. Also, there is no coating of the interior concrete floor.

Please acknowledge receipt of this Addendum No. 2 by signing where indicated below. **Please email a PDF copy of this signed addendum to stevent@wallacegroup.us.**

Company Name

Date

END OF ADDENDUM