

**Request for Proposal
for
Workshop/Storage Building at
1428 8th Street
Los Osos, California**

[Addendum #2](#)

[Revised May 18, 2018](#)

Issued by:

Los Osos Community Services District
2122 9th Street, Suite 102
Los Osos, CA 93402



The following is an addendum #2 to the original RFP for this project. The questions asked from the interested parties has provided an opportunity to revise the RFP with some detailed specifications and information. Please review the addendum and adjust any bids accordingly.

Explanation of revisions, additions or changes:

- The questions asked, and changes to RFP, are numbered, and presented as asked by contractors
- The answers provided are in bold
- The red font is a description of the location in the original RFP
- The Blue Font is the change for Addendum #2

1. What height will the eaves be?

Answer: The eaves will be 12 feet height. (Key Factors in Steel Building Design- Bullet #7)

Update: The eaves will be 16 feet in height, to accommodate the size of the roll up door and spring assembly.

2. Will the roof be gabled or single slope and what will be the roof pitch?

Answer: The roof will be a gabled roof with a 3/12 roof pitch. (Key Factors in Steel Building Design- Bullet #7)

Update: With the size of the eaves changing the height of the gables roof will now be approximately 19.57 feet high.

3. Change in Proposals Due Date

Update: New Due date will May 24, 2018 by 4:00 pm (Important Dates)

4. Inclusion of Bond documents

Update: Attached documents for Bonds, please submit with final bid documents (Proposal Submittal)