

**Los Osos Community Services District  
Minutes of the Utilities Advisory Committee Meeting  
October 15, 2025, at 5:30 p.m. at the District Office**

AGENDA ITEM	DISCUSSION	FOLLOW-UP
<b>1. Call to Order Flag Salute Roll Call</b>	<p>Chairperson Cesena called the meeting to order at 5:30 p.m.</p> <p><u>Roll Call:</u> James Bishop, Committee Member – Present Jan Harper, Committee Member – Present Leonard Moothart, Committee Member – Present Pam Ouellette, Committee Member – Present Matthew Tallone, Committee Member – Absent Matthew Fourcroy, Vice-Chairperson – Absent Chuck Cesena, Chairperson – Present</p> <p><u>Staff:</u> Ron Munds, General Manager Margaret Falkner, Utility Systems Manager Laura Durban, Administrative Services Manager</p>	
<b>2. Approve UAC Minutes of September 17, 2025</b>	<p>Chairperson Cesena presented the minutes for approval.</p> <p>Public Comment – None</p> <p><b>Committee Member Moothart moved to approve the meeting minutes of September 17, 2025. The motion was seconded by Committee Member Harper and the motion passed with a 3-0-1 vote with Committee Member Ouelette abstaining.</b></p>	<b>Action –File approved minutes.</b>
<b>3. Basin Management Committee Update</b>	<p>General Manager Munds presented a BMC update commenting on estimating sustainable yield, a draft BMC letter to the County, and a 50-year scenario in which the BMC adopted a sustainable yield of 2,000 acre-feet.</p> <p>Committee Member Ouellette inquired about the time frame to adjust/plug the Program C well and Golden State Water addressing the source of nitrates.</p> <p>Committee Member Moothart inquired about restricting Zone E pumping.</p> <p>General Manager Munds commented on well plugging and its costs, that the District may be able to plug Zone E and hope for future use. Responded that Golden State needs to respond but cannot stop pumping because of supply needs.</p> <p>Committee Member Bishop inquired about the sustainable yield after removing Zone E, the actual estimated sustainable yield, and how it reached 2,000 acre-feet.</p> <p>General Manager Munds responded that the 1830-acre-foot sustainable yield is current with pumping at a 5-year average, the current basin's yield is 1700-1800 acre-feet, and the model projected the 2,000-acre-foot number.</p> <p>General Manager Munds commented that the BMC recommends the County adopt a 0% growth rate, those on the 2025 waiting list should be carried over to 2026.</p> <p>The Committee discussed.</p> <p>Public Comment – None</p>	<b>Action - None</b>
<b>4. Utilities Department Report</b>	<p>Utility Systems Manager Falkner reported, including September 2025's water production, well site production, and runtime hours, water billing information, rainfall totals, and the call-out record.</p> <p>Chairperson Cesena inquired about production at 8th Street once SCADA issues are resolved.</p> <p>General Manager Munds commented that oversight of SCADA can only be run when someone is present. It will be very helpful once things are resolved.</p> <p>Public Comment – None</p>	<b>Action – None</b>

AGENDA ITEM	DISCUSSION	FOLLOW-UP
<b>5. Utilities Department Updates</b>	<p>General Manager Munds provided updates on the Program C Well with sampling starting and is expected to be operational in November; the SCADA system; the water resiliency intertie pipeline, which is progressing; and the 10th Street tank rehabilitation, which is underway, along with other projects.</p> <p>The Committee discussed.</p> <p>Public Comment – None</p>	<b>Action – None</b>
<b>6. Public Comments on items NOT on this Agenda</b>	Public Comment – None	
<b>7. Schedule the Next UAC Meeting</b>	The next meeting of the Utilities Advisory Committee is scheduled to be held on Wednesday, November 19, 2025, at 5:30 p.m. unless otherwise noticed.	
<b>8. Closing Comments by UAC Committee Members</b>	Committee Member Harper commented on voting.	
<b>9. Adjournment</b>	The meeting was adjourned at 6:16 p.m.	